


**NOTES:**

1. SAMPLING STATIONS SHALL BE 4.5' BURY WITH A 3/4" FIP INLET AND AN UNTHREADED NOZZLE.
2. ALL STATIONS SHALL BE ENCLOSED IN A LOCKABLE, NON-REMOVEABLE ALUMINUM-CAST HOUSING.
3. WHEN OPENED, THE STATION SHALL REQUIRE NO KEY FOR OPERATION AND THE WATER WILL FLOW IN AN ALL BRASS WATERWAY.
4. ALL WORKING PARTS SHALL ALSO BE OF BRASS AND REMOVEABLE FROM ABOVE GROUND WITHOUT DIGGING. EXTERIOR PIPE SHALL BE BRASS OR GALVANIZED.
5. A COPPER VENT TUBE WILL ENABLE EACH STATION TO BE PUMPED FREE OF STANDING WATER TO PREVENT FREEZING AND TO MINIMIZE BACTERIA GROWTH.
6. ECLIPSE NO. 88-SS SAMPLING STATION SHALL BE MANUFACTURED BY KUPFERLE FOUNDRY, ST. LOUIS, MO.

CONTRACTOR SUPPLIED MATERIALS:	
ITEM	MATERIALS
CURB STOP	MUELLER (B25209), FORD BALL (TYPE B44-333-Q) OR EQUAL
SERVICE LINE	TYPE "K" COPPER (CONTINUOUS, NO FITTINGS)
CURB BOX	TYLER SERIES 6500 W/ ADJUSTABLE SERVICE BOX (#94E)
BEDDING MATERIAL	WASHED SAND OR SQUEEGEE MATERIAL

DISTRICT SUPPLIED MATERIALS:	
3/4" AND 1" TAPS	
CORPORATION STOP	
INSULATOR	
SADDLE ON PVC MAINS	

REV. DATE:	06/2015	<b>SAMPLING STATION</b>
SCALE:	N.T.S.	
 NORTH TABLE MOUNTAIN WATER AND SANITATION DISTRICT		DWG. NO.
14806 WEST 52ND AVENUE GOLDEN, COLORADO 80403-1228		<b>W7</b>